



NetMeter-OMNI NEMA1 10"x10" Kit: Quick Guide



Example Installation of NEMA1 NetMeter-OMNI Enclosure

- Study the NetMeter-OMNI Installation Manual and follow safety procedures
- Assemble the NEMA1 chassis as shown above: power supply, NetMeter-OMNI, terminal blocks, ground wire, and 24V power hookup
- Mount the chassis and connect conduit as required
- Connect a current limited (15A or less) 120V, 208V, 240V supply to the power supply (optional finger-safe fuse holder may be used to provide disconnect and current limiting)
- Mount the Ethernet chassis receptacle into the desired 3/4" knockout (bottom of chassis preferred in order to minimize dust contamination)
- Ensure that all terminal screws are properly tightened using a torque screwdriver
- Secure the lid of the NEMA1 panel before applying power



24V NetMeter Power Hookup Wire